



Town of Surfside

RFQ 2022-04

Construction of Town of Surfside 96th Street Park

Addendum No. 4

Date Issued: July 26, 2022

To All Proposers:

Proposers for the above-referenced RFP shall take note of the following changes, additions, deletions or clarifications to RFP No. 2022-04, which in accordance with the RFQ Documents shall become a part of and have precedence over anything shown or described otherwise in the RFP.

THE FOLLOWING CHANGES ARE MADE TO THE RFP:

1. Sheets A-3.0 & A3.1 show R=30 insulation underside of the roof deck. Please provide information on material type and specifications.

Owens Corning Foamular 250 XPS R-30 Insulation

2. Please provide glazing specifications.

Glass values: U-factor=0.45 / SHGC (Solar Heat Gain Coefficient)=0.25

3. Please provide specifications for elevator.

TK Elevator - Evolution 100 - 2,100 lbs capacity

Responses have been included as a link under the RFP in the Town Clerk section of website.

<https://www.townofsursidefl.gov/departments-services/finance/bids-and-rfps>

PROPOSER:

NAME: _____

TITLE: _____

DATE: _____