



Department of Health
Bureau of Public Health Laboratories - Miami
 1325 N.W. 14th Avenue
 Miami, FL 33125
 Phone 305-324-2432

County: Dade
Type of Supply: Community Water System
Type of Sample: Compliance

System Owner: TOWN OF SURFSIDE
System ID: 4131424
System Phone:
Collector/Phone: JACK A / 305 623 3551
Collection Addr: VARIOUS
 SURFSIDE, FL 33154

Report To:
 TOWN OF SURFSIDE
 9293 HARDING AVE
 SURFSIDE, FL 33154

Date Received: 2/16/2021 2:33:00PM
Date Analyzed: 2/16/2021 4:00:00PM
Date Reported: 2/17/2021 5:07:04PM
Sample Temp (°C): 12 On Ice
Chlorine Check: Not Detected
District:

| Collect ID | Sample Point | Date Collected | Raw /Dist | Res'd CI | pH | Total Collform | E.coli | HPC cfu/mL | Lab ID |
|------------|------------------|-------------------|-----------|----------|-----|----------------|--------|------------|-------------|
| 6 | 9417 HARDING AVE | 2/16/2021 11:30AM | Dist | 1.5 | 8.4 | Absent | Absent | | MED21000542 |
| 7 | 9140 COLLINS AVE | 2/16/2021 11:50AM | Dist | 1.25 | 8.4 | Absent | Absent | | MED21000543 |

Lab Comments/Qualifiers:

Water sample, as received
 considered bacteriologically
 safe for drinking purposes.
Florida Department of Health
Miami Dade County

Disinfectant Residuals Avg: 1.43
Disinfectant Residuals Method:
Disinfectant Analysis Certified Operator #:

All Tests Performed In Accordance with NELAC Standards
 *The Total Collform Test includes E. coli.

Coliform/E. Coli Method: SM 9223 B

Authorized By: Stephen White
LIMS Report #: 10259708

DEP/DOH Use Only

- Satisfactory
- Incomplete Collection Information
- Repeat Samples Required
- Replacement Samples Required

Date Reviewed by DEP/DOH: 02/18/2021
DEP/DOH Reviewing Official: [Signature]

Final



NELAC: E16533

Department of Health
Bureau of Public Health Laboratories - Miami
 1325 N.W. 14th Avenue
 Miami, FL 33125
 Phone: 305-324-2432

County: Dade
Type of Supply: Community Water System
Type of Sample: Compliance

System Owner: TOWN OF SURFSIDE
System ID: 4131424
System Phone:
Collector/Phone: JACK A / 305 623 3551
Collection Addr: VARIOUS
 SURFSIDE, FL 33154

Report To:
 TOWN OF SURFSIDE
 9293 HARDING AVE
 SURFSIDE, FL 33154

Date Received: 2/16/2021 2:33:00PM
Date Analyzed: 2/16/2021 4:00:00PM
Date Reported: 2/17/2021 5:07:03PM
Sample Temp (°C): 11 On Ice
Chlorine Check: Not Detected
District:

| Collect ID | Sample Point | Date Collected | Raw /Dist | Res'd CI | pH | Total Coliform | E.coli | HPC cfu/mL | Lab ID |
|------------|------------------|-------------------|-----------|----------|-----|----------------|--------|------------|-------------|
| 1 | 8750 COLLINS AVE | 2/16/2021 10:00AM | Dist | 1.5 | 8.4 | Absent | Absent | | MED21000537 |
| 2 | 8855 COLLINS AVE | 2/16/2021 10:20AM | Dist | 1.25 | 8.4 | Absent | Absent | | MED21000538 |
| 3 | 9056 COLLINS AVE | 2/16/2021 10:40AM | Dist | 2.0 | 8.4 | Absent | Absent | | MED21000539 |
| 4 | 8826 DICKENS AVE | 2/16/2021 10:55AM | Dist | 1.25 | 8.4 | Absent | Absent | | MED21000540 |
| 5 | 1000 89 ST | 2/16/2021 11:15AM | Dist | 1.25 | 8.4 | Absent | Absent | | MED21000541 |

Lab Comments/Qualifiers:

1 (MED21000537) Sample(s) >10°C. Does not meet NELAC standards.

Water sample, as received considered bacteriologically safe for drinking purposes.
Florida Department of Health
Dade County

Disinfectant Residuals Avg:
 Disinfectant Residuals Method:
 Disinfectant Analysis Certified Operator #:

All Tests Performed in Accordance with NELAC Standards
 *The Total Coliform Test includes E. coli.

Coliform/E. Coll Method: SM 9223 B

Authorized By: Stephen White
 LIMS Report #: 10259702

DEP/DOH Use Only

Satisfactory
 Incomplete Collection Information
 Repeat Samples Required
 Replacement Samples Required

Date Reviewed by DEP/DOH: 02/18/2021
 DEP/DOH Reviewing Official: [Signature]

Final