



NELAC: E16533

Department of Health
Bureau of Public Health Laboratories - Miami
1325 N.W. 14th Avenue
Miami, FL 33125
Phone: 305-324-2432

County: Dade
Type of Supply: Community Water System
Type of Sample: Compliance

System Owner: TOWN OF SURFSIDE
System ID: 4131424
System Phone:
Collector/Phone: JACK A / 3056233551
Collection Addr: VARIOUS SURFSIDE, FL 33154

Report To: TOWN OF SURFSIDE
9293 HARDING AVE
SURFSIDE, FL 33154

Date Received: 8/19/2021 2:34:00PM
Date Analyzed: 8/19/2021 3:00:00PM
Date Reported: 8/20/2021 4:52:21PM
Sample Temp (°C): 14 On Ice
Chlorine Check: Not Detected
District:

Table with 10 columns: Collect ID, Sample Point, Date Collected, Raw /Dist, Res'd CI, pH, Total Coliform, E.coli, HPC cfu/mL, Lab ID. Contains 5 rows of sample data.

Lab Comments/Qualifiers:

1 (MED21002922) Sample(s) >10°C. Does not meet NELAC standards.
2 (MED21002923) Sample(s) >10°C. Does not meet NELAC standards.


Water sample, as received
considered bacteriologically
safe for drinking purposes.
Florida Department of Health
Miami Dade County

Dupl.

Disinfectant Residuals Avg:
Disinfectant Residuals Method:
Disinfectant Analysis Certified Operator #:
All Tests Performed in Accordance with NELAC Standards
*The Total Coliform Test includes E. coli.
Coliform/E. Coli Method: SM 9223 B
Authorized By: Stephen White
LIMS Report #: 10990647

DEP/DOH Use Only
Satisfactory
Incomplete Collection Information
Repeat Samples Required
Replacement Samples Required
Date Reviewed by DEP/DOH: 08/20/2021
DEP/DOH Reviewing Official:

Final



Department of Health
Bureau of Public Health Laboratories - Miami
 1325 N.W. 14th Avenue
 Miami, FL 33125
 Phone: 305-324-2432

County: Dade
 Type of Supply: Community Water System
 Type of Sample: Compliance

System Owner: TOWN OF SURFSIDE
 System ID: 4131424
 System Phone:
 Collector/Phone: JACK A / 305 623 3551
 Collection Addr: VARIOUS
 SURFSIDE, FL 33154

Report To:
 TOWN OF SURFSIDE
 9293 HARDING AVE
 SURFSIDE, FL 33154

Date Received: 8/19/2021 2:34:00PM
 Date Analyzed: 8/19/2021 3:00:00PM
 Date Reported: 8/20/2021 4:52:21PM
 Sample Temp (°C): 14 On Ice
 Chlorine Check: Not Detected
 District:

Collect ID	Sample Point	Date Collected	Raw /Dist	Res'd CI	pH	Total Coliform	E.coli	HPC cfu/mL	Lab ID
6	9417 HARDING AVE	8/19/2021 11:40AM	Dist	1.5	8.6	Absent	Absent		MED21002927
7	9140 COLLINS AVE	8/19/2021 12:00PM	Dist	2.25	8.6	Absent	Absent		MED21002928

Lab Comments/Qualifiers:

Water sample, as received
 considered bacteriologically
 safe for drinking purposes.
 Florida Department of Health
 Miami-Dade County

Disinfectant Residuals Avg: 1.85
 Disinfectant Residuals Method:
 Disinfectant Analysis Certified Operator #:
 All Tests Performed in Accordance with NELAC Standards
 *The Total Coliform Test includes E. coli.
 Coliform/E. Coli Method: SM 9223 B
 Authorized By: Stephen White
 LIMS Report #: 10963916

DEP/DOH Use Only

Satisfactory
 Incomplete Collection Information
 Repeat Samples Required
 Replacement Samples Required

Date Reviewed by DEP/DOH: 08/20/21
 DEP/DOH Reviewing Official: [Signature]

Final