

DRINKING WATER BACTERIOLOGICAL SAMPLE COLLECTION AND LABORATORY REPORTING FORMAT

Miami-Dade Water & Sewer Department
 John E. Preston Water Quality Laboratory
 1100 W. 2nd Ave.
 Hialeah, Florida 33010
 Lab Certification Number E56731
 Coreen Philip, (786) 552-4738



Collection Date:	8/16/2022	
Lab Receipt Date:	8/16/2022	Lab Receipt Time: 14:00
Setup Date:	8/16/2022	Setup Time: 16:15
Analysis Date:	8/17/2022	Analysis Time: 15:00

Sample Acceptance Criteria

Sample Preservation on ice not on ice 8.4 °C

Disinfection Check Not Detected mg/L

This sample does not meet the following NELAC requirements:

Report Number : 220817140901 Sub-Contract Lab ID _____

Analysis Requested: (please X all that applies)

HPC Standard Coliform Test MMO/MUG Other

System Name : Town of Surfside

System Address: 9293 Harding Ave.

System or Owner's Phone # : _____

Collector: Isaac Carvajalino

Analyst: Assad Jamil

PWS I.D.

4	1	3	1	4	2	4
---	---	---	---	---	---	---

City : Surfside

Fax # : _____

Collector's Phone # : 786-552-4738

Type of Supply: Community Water System Well Noncommunity Water System Nontransient Noncommunity Water System

Reason for Sampling (X only one) Routine Compliance Main Clearance

Repeat Main Break Wells Replacement Other

Collection Date: 8/16/2022

Sample Number	Sample Point (Location or Specific Address)	Collection Time	Sample Type ¹	Disinfectant Res'd (mg/L)		pH	Non Coliform	Total Coliform SM9222B	Confirm E. Coli	Data Qualifier ²	LIMS Assigned Number
				Free	Total						
1	8750 Collins Ave.	11:34	D		1.6			A			AR32416
2	8826 Dickens Ave.	11:49	D		0.5			A			AR32417
3	1000 89 St.	12:00	D		0.8			A			AR32418
4	8855 Collins Ave.	12:29	D		1.2			A			AR32419
5	9056 Collins Ave.	12:42	D		1.2			A			AR32420
6	9140 Collins Ave.	12:54	D		0.9			A			AR32421
7	9400 Harding Ave.	13:20	D		2.8			A			AR32422

Average of disinfectant residuals for routine and repeated samples. (Complete for community and nontransient non-community systems serving populations up to and including 4900. Do not include raw or plant samples in the average.)

Disinfectant Residual Analysis Method: DPD Colorimetric Other _____

Person performing analysis is (Please see instructions on reverse):

A Certified Operator # _____ Employed by a Certified Lab

Supervised by a Certified Operator # _____

1.29

²Defined in Florida Administrative Code Rule 62-160, Table 1

Results relate only to items tested for the sample received in the JEPWQL. This report shall not be reproduced except in full, without the written approval of the JEPWQL.

All tests are performed in accordance with NELAC standards.

Date PWS notified by lab of positive results: _____

Date State notified by lab of positive results: _____

Name and Mailing Address of Person To Receive Report

Dr. Samir Elmir, P.E.

Drinking Water Program Administrator

State of Florida

Department of Health

1725 N.W. 167 Street, Suite 119

Miami, Florida 33056

Reviewing Official: *C Philip*

Title: Chemist 3

DEP/DOH USE ONLY

Satisfactory

Incomplete Collection Information

Repeat Samples Required

Replacement Samples Required

Date Reviewed by DEP/DOH: 09/12/2022

DEP/DOH Reviewing Official: _____

¹DEP Sample Type Codes: D = Distribution (Routine Compliance); C = Repeat or Check; R = Raw; N = Entry of Distribution; P = Plant Tap; S = Special (Clearance, etc.)

Analysis Methods: MF = SM9222B & D; MMO/MUG = SM9223B; HPC = SM9215B; pH = SM45000-H+; Color = SM2120B; Turbidity = SM2130B

Result: A = Total coliforms are absent; P = Total coliforms are present; C = confluent growth; TNTC = too numerous to count

(62-550.730 Reporting Form - Effective 01/95, Revised 01/04)